



Forschungsbeitrag

## **Problems in Catalyst Recirculation in a Catalytic Cracking Plant**

Bearbeitet von am 22. Okt. 2023

[Published in bulk solids handling, Vol. 2 \(1982\) No. 2](#)

In a fluidized bed catalytic cracking plant, smooth catalyst recirculation between a reactor and a regenerator is important. Spent catalyst flows at rates up to 120 tonne min<sup>-1</sup> from the reactor down a standpipe to the regenerator. The regenerated catalyst flows through another standpipe to be transported back to the reactor via a riser. Operating problems such as insufficient pressure build-up in the pipes pressure reversal, inadequate solid flow flow instability or complete stoppage sometimes occur. These problems can often be traced to mal-operation in the standpipes. Remedial action by injecting steam (aeration) into the standpipes to counteract compressibility of the gas sometimes produces an effect counter to that intended. In this paper the causes of operating problems are discussed in the light of recent advances in the understanding of gas-solid flow in standpipes (Dries, 1980; Ginestra et al. 1980; Jones et al. 1980). In particular the effects of slide valve opening aeration gas injection rate and catalyst size on flow instability will be discussed.

A catalytic cracking plant usually consists of reactor, stripper and regenerator interconnected through pipes known as standpipes or risers as depicted in Fig. 1.

Hydrostatic head difference In the sides of the circuit enables the catalyst to circulate at enormous rates of up to 120 tonne min<sup>-1</sup> (Matsen, 1976). On the

regenerator side, solids descend down the standpipe by gravity in a dense form, through the slide valve then are conveyed pneumatically up the riser into the reactor in a very dilute fashion.

The main function of a standpipe is often to transport solid (and gas) from a region of low pressure to a region of higher pressure. During normal operation pressure increases in the downwards direction as a result of gravity head and there is a positive pressure difference across the slide valve (i.e.,  $P_2 > P_3$  In Fig. 1). The slide valve controls solid circulation rate and prevents oil vapour from getting into the regenerator which otherwise may form an explosive mixture in the regenerator. Such occurrence is prevented in practice by the automatic shut off of the slide valve when ( $P_2$  minus  $P_3$ ) falls below a preset value. Such valve shut off can lead to costly shutdown of the entire plant. Thus a stable and adequate pressure build-up in the standpipe is important to ensure smooth catalyst circulation. In this paper, the causes of the common problems will be discussed in the light of recent advances in understanding of standpipe flow.