

**Calculation Table Pressure Conveying**

Table calculation												
Part	Part description	Length(m)	v-gas	v-product	Pressure drop	v-wall / v-susp	residence time	mass kg	kW	% kW	Bend loss kW	Sediment % kW
1	Intake	1	5.91	5.46	582	2.33	0.195	4	0.5	1.4		
2	Pipe	2	5.92	5.65	860	2.4	0.551	8	0.2	0.6		
3	Bend		5.92	3.34	860		0.6241	1	0		0.2	0.5
4	Pipe	5	6.04	5.76	1738	2.42	1.5041	19	0.8	2.1		
5	Bend		6.04	2.74	1738		1.5829	1	0		0.2	0.6
6	Pipe	5	6.63	5.92	4871	2.53	2.4659	19	3.1	8		
7	Bend		6.63	3.52	4871		2.5365	1	0		0.2	0.6
8	Pipe	20	7.1	6.7	7554	2.61	5.6236	68	2.9	7.5		
9	Bend		7.1	5.14	7554		5.6506	0	0		0.1	0.4
10	Pipe	25	7.87	7.37	10719	2.74	9.2096	78	3.7	9.8		
11	Bend		7.87	5.66	10719		9.234	0	0		0.2	0.5
12	Pipe	5	8.11	7.57	11514	2.78	9.9079	14	1	2.6		
13	Bend		8.11	3.99	11514		9.9653	1	0		0.4	1.1
14	Pipe	15	11.2	9.64	18295	3.24	11.7743	39	10.4	27		
15	Bend		11.2	5.7	18295		11.8175	0	0		0.6	1.6
16	Pipe	2	11.65	10.45	19005	3.3	12.0225	4	1.3	3.4		
17	Bend		11.65	8.03	19005		12.0397	0	0		0.4	1.1
18	Pipe	25	15.73	13.49	23328	3.81	14.1607	45	9.6	24.8		
19	Bend		15.73	7.96	23328		14.1915	0	0		1.2	3.1
20	Pipe	5	18.12	15.07	24911	4.08	14.5515	7	4.4	11.4		
21	Bend		18.12	9.12	24911		14.5787	0	0		1.4	3.8
22	Outlet		18.12	9.12	24911		14.5787		0.0593			
23	Filter	36	m <sup>2</sup>	0.5	mm/min	25000	14.5787		0.2657		88	mmWC

**Progress**  
 Filter:   
 Iteration: 

**Buttons:** Back to Menu, Print calculation, Change product, New Calculation, Calculation results

**Calculation results pressure conveying**

Calculation results													
Client	Kolmykov Andrey	Capacity	74,1	tons/hr									
Filepath	c:\Vdandr.txt	Pressure	25000	mmWC									
Product	Cement	Booster pressure	0	mmWC									
Convey distance horizontal	90.00000 m	Back pressure	0	mmWC									
Convey distance vertical	20 m	Pressure drop	25000	mmWC									
Total conveying length	110 m	Loading ratio	57,9										
Number of Bends	10	Empty pipeline pressure	814	mmWC									
Compressor displacement	0.3 m <sup>3</sup> /sec	Residence time	14,57	seconds									
Booster displacement	0 m <sup>3</sup> /sec	Re-number * 10 <sup>5</sup>	1.583										
		Mixture density	69,2	kg/m <sup>3</sup>									
		Mass of material in pipeline	321	kg									
<b>Vessel system</b>													
Installation system	<input checked="" type="radio"/> 2-vessel system <input type="radio"/> 3-vessel system	<input type="radio"/> Rotary lock feeder <input type="radio"/> screw feeder	<input type="radio"/> silo unloading airslides										
Vessel factor	1000	tons/hr/bar(a)	vessel capacity	285,7	tons/hr								
Nominal capacity	70	tons/hr	Vessel content	0,33	tons								
vessel volume	0,7 m <sup>3</sup>	m <sup>3</sup>	pipe content	321,8	kgs								
Vessel product volume	0,3 m <sup>3</sup>	m <sup>3</sup>											
pipevolume	1,89 m <sup>3</sup>	m <sup>3</sup>											
pressure begin pressurizing	-0.05 bar												
pressure valve open	2,5 bar												
temperature begin pressurizing	35 C												
temperature after pressurizing	60 C												
pressurizing time	4,3 seconds												
Discharging time	16 seconds												
purgung time	10,9 seconds												
valve time	2 seconds												
overlaptime													
cycletime	33,3 seconds												
Number of kettles/hr	108 -												
<b>Table calculation</b>													
Begin capacity	74,1 tons/hr												
Begin pressure	25000 mmWC												
pressure decrement	1125 mmWC												
lowest pressure	2500 mmWC												

**Kettle capacity>capacity** Calculate system capacity Calculate table

**Buttons:** Back to Menu, New Calculation, Print calculation result

Table calculation

Client	Kalmykov Andrey	Convey distance horizontal	90	m	Pump displacement	0,3	m <sup>3</sup> /sec		
Filepath	c:\V\andr.txt	Convey distance vertical	20	m	Booster displacement	0	m <sup>3</sup> /sec at 2.5 bar		
Product	Cement	Total conveying length	110	m					
		Number of Bends	10						
		Pipe diameter begin	148	mm					
		Pipe diameter end	148	mm					
					Gas volume end	0,3264	m <sup>3</sup> /sec		
<b>Pressure conveying</b>									
Pressure bar	pipe line capacity tons/hr	system capacity tons/hr	Number of kettles/hr	Solid Loading Ratio SLR	gas velocity begin m/sec	gas velocity end m/sec	energy consumption kWh/ton	residence time seconds	sediment
25	74,1	35	108	< Kettle range> >capacity	57,9	5,9	18,1	2,09	No sedimentation
2,3875	72,4	35	107,6	>capacity	56,4	6	18,1	2,02	No sedimentation
2,275	70,7	35	107,1	>capacity	54,9	6,2	18,1	1,96	No sedimentation
2,1625	68,9	35	106,5	>capacity	53,3	6,4	18,2	1,89	No sedimentation
2,05	67	34	105,9	>capacity	51,8	6,6	18,2	1,87	No sedimentation
1,9375	65,1	34	105,1	>capacity	50,1	6,8	18,2	1,8	No sedimentation
1,825	63,1	34	104,2	>capacity	48,4	7,1	18,2	1,73	No sedimentation
1,7125	61,1	34	103,1	>capacity	46,7	7,3	18,3	1,66	No sedimentation
1,6	59	33	101,9	>capacity	45	7,6	18,4	1,64	No sedimentation
1,4875	56,7	33	100,4	>capacity	43	7,9	18,3	1,57	No sedimentation
1,375	54,3	32	98,7	>capacity	41,1	8,3	18,4	1,54	No sedimentation
1,2625	51,9	31	96,7	>capacity	39,1	8,6	18,4	1,52	No sedimentation
1,15	49,2	31	94,3	>capacity	36,9	9,1	18,4	1,44	No sedimentation
1,0375	46,4	30	91,5	>capacity	34,7	9,5	18,5	1,41	No sedimentation
0,925	43,3	29	88,1	>capacity	32,2	10,1	18,5	1,38	No sedimentation
0,8125	39,9	27	84	>capacity	29,6	10,7	18,5	1,39	No sedimentation
0,7	36,1	26	78,8	>capacity	26,6	11,3	18,6	1,35	No sedimentation
0,5875	31,8	23	72,2	>capacity	23,3	12,1	18,6	1,42	No sedimentation
0,475	26,7	20	63,6	>capacity	19,5	13	18,7	1,52	No sedimentation
0,3625	20,6	17	51,8	>capacity	14,9	14	18,8	1,65	No sedimentation
0,25	13,2	11	35,6	>capacity	9,5	15,2	18,9	2,33	No sedimentation
Empty pipeline system pressure drop				815	mmWC				
<a href="#">Back to Menu</a>		<a href="#">New Calculation</a>		<a href="#">Print table</a>					